

## Certified Validation Report Template, Part A: Provided by Validator

### Audit Information:

**Water System Name:** South Feather Water & Power Agency - Bangor

**Public Water System Identification (PWSID)<sup>1</sup>:** CA 0410012

<sup>1</sup>List only 1 PWSID, which should match the PWSID on the FWAS Instructions Tab. For Special cases where multiple water systems are connected with permanent two-way interties, list those additional PWSIDs in the **Notes** below and describe the water distribution system(s) configuration.

### PWSID and Water System Configuration Notes (Provided to Validator by Water System):

**Audit Period:** Calendar Year 2019

**Validation Date:** 5/14/2021

**Sufficient Supporting Documents Provided:** Yes

**Validation Findings & Confirmation Statement:**

### Key Audit Metrics:

Data Validity Score: 59      Data Validity Band (Level): Band III (51-70)

ILI: Not Valid      Real Loss: N/A      Apparent Loss: 41.98 gallons/connection/day

Non-revenue water as percent of cost of operating system: 0.1%

### Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☐

*If not, rejected recommendations are included here:*

### Validator Information:

Water Audit Validator: Allison Cronk

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided